

2017 Water Audit
Certified Validation Report



Part A: Provided by Validator

Audit Information:

Utility: San Gabriel County Water District PWS ID: 1910144
System Type: Potable Audit Period: Calendar 2017 Utility Representation: Anthony Agobian
Validation Call Date: 9/20/2018

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 55 Data Validity Band (Level): Band III (51-70)
ILI: 1.96 Real Loss: 31.06 (gal/conn/day) Apparent Loss: 8.25 (gal/conn/day)

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34. All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

Validator Information:

Water Audit Validator: Greg Ripperger

Validator Qualifications: Water Audit Validator Certificate

2017 Water Audit
Certified Validation Report



Part B: Provided by Utility

Water Supplier Name: San Gabriel County Water Di: Water Supplier ID Number: 1910144

Water Audit Period: Calendar 2017

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss, as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software.

Executive Name (Print):

James Prior

Executive Position:

General Manager

Signature:

Date:

9/27/18